

Accessibility of Polling Sites

185 of 185

61 - Yes / 72 - Modify / 52 - No 33% Accessible
With Modifications 72%

Precinct Number	Precinct Name	Polling Site	Accessible?	Recommendations
0201	Amwell 1	Lone Pine Community Center	Modify	Sign parking spaces, prop side door with ramp.
0202	Amwell 2	Amwell Vol. Fire Dept.	Modify	Designate parking spaces.
0401	Bentleyville 1	Bentleyville Vol. Fire Dept.	Modify	Designate parking, prop doors.
0402	Bentleyville 2	Bentleyville Vol. Fire Dept.	Modify	Designate parking, prop doors.
0501	Blaine	Blaine Twp. Bldg.	Modify	Sign parking spaces for now.
0804	California 4	United Christian Church	Modify	Designate parking and prop doors.
0913	Canonsburg 1-3	White Eagles	Modify	Gain permission to park next door, sign parking spot.
0914	Canonsburg 1-4	First Street Elementary School	Modify	Designate parking spaces.
0921	Canonsburg 2-1	VFW Post 191	Modify	Sign parking spots to bring them up to ADA standards.
0931	Canonsburg 3-1	Central Elementary	Modify	Designate parking or hire policeman to allow parking in the loading zone at front of building (far away).
1103	Carroll 3	Carroll Vol. Fire Dept.	Modify	Designate parking.
1203	Cecil 3	Mike's Service Mart	Modify	Voting would need to occur in garage, as opposed to small storage room because doorway is narrow. Parking would need to be designated.
1204	Cecil 4	Cecil Vol. Fire Dept. #3	Modify	Ascertain if closer parking would be an option. Prop doors open on election day.
1205	Cecil 5	Cecil Township VFD #2	Modify	Sign parking spots to bring them up to ADA standards. Prop doors on election day.
1206	Cecil 6	Cecil Twp. Fire Dept. Lawrence	Modify	Contact Donald Hindman prior to election day to be sure the ramp has been completed. (724) 941-6627
1304	Centerville 4	Centerville VFD Richeyville	Modify	Sign parking spaces.
1305	Centerville 5	Vestaburg New Hill JT Auth.	Modify	Designate parking, modify door handles.
1306	Centerville 6	Centerville VFD Denbo-Vesaburg	Modify	Designate parking spaces.
1401	Charleroi 1	Charleroi Senior Center	Modify	Designate parking spaces.
1501	Chartiers 1	Western Area Career & VoTech	Modify	Designated spots are at rear of building, so signage is needed to direct voters to polling location.

Accessibility of Polling Sites

185 of 185

61 - Yes / 72 - Modify / 52 - No 33% Accessible
With Modifications 72%

1503	Chartiers 3	Our Lady of Miraculous Medal CCD Center	Modify	Prop doors.
1506	Chartiers 6	Chartiers Houston Library	Modify	Designate parking. Signage to denote accessible entrance (rear library entrance).
1901	Cross Creek 1	Cross Creek Presby. Church	Modify	Temporary Ramp is used - I have not seen this - call before election day. Otherwise, fine!
1902	Cross Creek 2	Cross Creek Twp. Bldg	Modify (?)	Prop interior doors, sign parking lot. Pave parking lot.
2001	Deemston	Deemstown Boro Bldg	Modify	Prop doors, designate parking, modify door handles.
2101	Donegal 1	Donegal Twp. Bldg	Modify (?)	Designate parking spaces. Pave lot.
2202	Donora 2	Emanuel Baptist Church	Modify	Designate parking, prop doors.
2205	Donora 5	Calvary Presby. Church	Modify	Designate parking, modify door handles.
2207	Donora 7	St. Johns Episcopal Church	Modify	Designate parking, prop doors.
2403	East Beth 3	Vestaburg New Hill JT Auth.	Modify	Designate parking, modify door handles.
2601	East Washington 1	First Christian Church	Modify	Sign parking spaces.
2602	East Washington 2	First Christian Church	Modify	Sign parking spaces.
2701	Elco	Elco Boro Bldg	Modify	Designate parking.
2801	Ellsworth	Ellsworth/Somerset VFD Social Hall	Modify	Designate parking.
2904	Fallowfield 4	Fallowfield Fire Dept	Modify	Designate parking/loading zone.
3102	Hanover 2	Hanover Vol Fire Dept	Modify	Prop door at top of ramp since handle is a knob.
3201	Hopewell	Hopewell Twp. Bldg	Modify	Designate parking spaces.
3401	Independence 1	Avella Community Center	Modify	Prop interior doors, sign parking lot. Eventually, pave parking lot.
3501	Jefferson	Jefferson Twp VFD	Modify (?)	If a person could enter through garage doors. Needs to designate parking spaces. Pave lot.
3601	Long Branch	Long Branch Boro Bldg	Modify	Parking lot is grass/gravel - otherwise this site is fine.
3801	Midway	Midway Community Center	Modify	Voting would need to occur in an upstairs room. Are council chambers an option?
3911	Monongahela 1	Robert's Carstar	Modify	Designate parking spaces.
3923	Monongahela 2-3	Hilltop Bar	Modify	Change door handles, denote accessible entrance is bar entrance for handicapped voters.

Accessibility of Polling Sites

185 of 185

61 - Yes / 72 - Modify / 52 - No 33% Accessible
With Modifications 72%

3932	Monongahela 3-2	Monongahela School Dist.	Modify	Designate parking spaces since the existing handicapped spaces are not used on election day. Remove center post from double doors to create a wider space.
4101	Mt. Pleasant 1	Mt Pleasant VFD	Modify	Prop interior doors.
4201	McDonald	McDonald Trail Station	Modify	Will be modified before election day by owners. Check on signage etc.
4301	New Eagle 1	New Eagle VFD Social Hall	Modify	Designate parking spaces.
4302	New Eagle 2	New Eagle VFD Social Hall	Modify	Designate parking spaces and entrance that is to be used.
4401	North Beth 1	North Beth Community Center	Modify	Designate parking, identify rear entrance as accessible.
4601	North Franklin 1	North Franklin VFD	Modify	Sign parking spaces
4602	North Franklin 2	North Franklin VFD - Cleveland Rd.	Modify	Sign parking spaces
4603	North Franklin 3	North Franklin VFD	Modify	Sign parking spaces
4702	North Strabane 2	Wylandville Elementary	Modify	Prop doors. Curb cut is FAR away but present.
4703	North Strabane 3	SNPJ Club	Modify	Post signage designating accessible (club) entrance.
4802	Nottingham 2	Thomas Presby Church	Modify	Designate parking spaces.
4933	Peters C-3	Center Presby Church	Modify	Post signage designating accessible entrance, door is usually locked - wireless doorbell needed at this door. Designate closer parking spot?
4943	Peters D 3	Crossroads Church of Christ	Modify	Post signage designating accessible entrance and parking spot. Driveway is steep - this is a concern!
5201	Smith 1	Slovan VFW	Modify	Designate parking spaces.
5202	Smith 2	St Ann Church	Modify	Designate parking spaces in rear of building.
5203	Smith 3	Burgettstown High School	Modify	Prop doors.
5206	Smith 6	Barbush Langloth Municipal Corp.	Modify	Designate parking spaces.
5701	Stockdale	Stockdale Boro Bldg	Modify	Change door handles, create larger parking space by blocking adjacent.
5801	Twilight	Twilight Boro Bldg	Modify	Change door handles.
5903	Union 3	Geracitano Construction	Modify	Designate parking, modify door handles.

Accessibility of Polling Sites

185 of 185

61 - Yes / 72 - Modify / 52 - No 33% Accessible
With Modifications 72%

5907	Union 7	South Park Mobile Estates	Modify	Needs designated parking near a curb cut.
6001	West Alexander	West Alexander VFD	Modify	If a person could enter through garage doors. Needs to designate parking spaces.
6201	West Brownsville 1	West Brownsville VFD	Modify	Parking on a slope, but otherwise fine.
6301	West Finley 1	West Finley VFD	Modify	Disgnate parking spaces.
6502	West Pike Run 2	Daisytown United Presby Church	Modify	Designate parking, prop doors.
6641	Washington 4-1	First Baptist Church	Modify	Designate Parking
6661	Washington 6-1	St Paul AME Church	Modify	Parking spaces are in the middle of the lot and unsigned, couldn't they be brought closer and signed?
6681	Washington 8-1	W. Washington United Medthodist	Modify	Doors are 29" double doors, prop them. Sidewalk isn't 100% flat, there is a 1" lip at part of it, needs maintenance.
0802	California 2	New Adventure Learning Ctr.	No	Exterior ramp into building is 12.8%
0803	California 3	East Pike Run Sportsmans Club	No	Gravel lot, grass walkway to building, lip to get on ramp, ramp is 18.4%
0922	Canonsburg 2-2	PA Army National Guard Armory	No	Steps to entrances, no designated parking, gravel lot.
0933	Canonsburg 3-3	St. Michaels Byzantine Church	No	
1001	Canton 1	Polish Club	No	Parking on steep hill, steps to entrance.
1101	Carroll 1	Victory Hill Civic and Social Center	No	Entrance Used is not accessible
1105	Carroll 5	American Legion #949	No	Sign parking spaces, make man made "curb cut" more stable, ramp 1" threshold, interior door 27".
1202	Cecil 2	Millers Run Grange Venice	No	30" doors, ramp is 17.5%, 34" pathway, no parking, grass to walkway
1303	Centerville 3	St. Paul United Methodist Church	No	Door is too narrow 30", parking lot is gravel
1402	Charleroi 2	First United Methodist Church	No	Steps to every entrance.
1406	Charleroi 6	Holy Ghost Byzantine Church	No	Entrance Used is not accessible
1502	Chartiers 2	Planka Sportsmans Club	No	1.5" threshold to door, no parking, no curb cuts.
1601	Claysville	First Baptist Church of Claysville	No	Designate parking spaces, prop double doors, ramp the threshold.
1701	Coal Center	Coal Center Presby Church	No	Steps to every entrance, no parking.

Accessibility of Polling Sites

185 of 185

61 - Yes / 72 - Modify / 52 - No 33% Accessible
With Modifications 72%

2102	Donegal 2	Zion United Methodist Church	No	Where does voting occur? If in the church, ramps are STEEP but get you there. If downstairs, no accessible entrance from what I could see.
2204	Donora 4	Donora Elementary	No	Slope of exterior ramp 9%, double doors are 28" -- prop.
2401	East Beth 1	Tri County JT Municipal Auth.	No	27" entryway inside, 1.5" threshold, no parking, surface inaccessible.
2402	East Beth 2	East Beth Twp. Bldg	No	Gravel, unsigned parking lot, 1" threshold to door
2404	East Beth 4	St. Thomas Catholic Church	No	Steps to every entrance.
2502	East Finley 2	East Finely Twp. Bldg	No	Door is narrow, parking lot is gravel and unsigned and there is a step up to the concrete pad that leads to the door. The room itself is narrow, how is it set up on election day? Would there be ample turning radius?
2902	Fallowfield 2	Ottor Club	No	Steps to entrances, no parking.
3001	Finleyville	Finleyville Community Center	No	2" threshold, 30" door, no parking.
3101	Hanover 1	Florence Presby Church	No	Parking lot is gravel and unlit. Disgnation of parking spots as well as resurfacing the driveway and path to the door would be necessary.
3921	Monongahela 2-1	Free Methodist Church	No	Ramp is 10.6%, lip to ramp, no designated parking.
4001	Morris	Prosperity VFD	No	No parking, ramp is 10%, entrance to deck is 33" step to door is 4" door knobs
4103	Mt. Pleasant 3	First Baptist Church of Westland	No	31" sidewalk, ramp is 20.8%, door does not open fully.
4104	Mt. Pleasant 4	Mt. Pleasant VFD Southview	No	Designate parking, ramp thresholds, change door handles.
4402	North Beth 2	Mt. Calvary Lutheran Church	No	No parking, grass to entrance, steps to entrances.
4705	North Strabane 5	Chartiers Hill Presby Church	No	Parking needs to be signed, slope of hill to get to entrance is 13.3 then 13.6% door is 29"
5001	Robinson 1	Robinson Presby Church	No	Gravel lot, ramp is 12% to building, no designated parking, door handles are knobs.
5002	Robinson 2	Raccoon Presby Church	No	

Accessibility of Polling Sites

185 of 185

61 - Yes / 72 - Modify / 52 - No 33% Accessible
With Modifications 72%

5003	Robinson 3	Robinson Twp. Bldg	No	Thresholds are 1". No parking near ramp.
5101	Roscoe	Roscoe Boro Bldg	No	No curb cuts, no parking, no pathway to door with accessible threshold.
5204	Smith 4	Cherry Valley Sportsmans Club	No	No parking, inaccessible surface of walkway, door is too narrow (but double) and threshold is greater than .5"
5205	Smith 5	Atlasburg Chuch of Nazarene	No	Threshold is about 2" to enter building, parking is non existant and drop off area is gravel.
5207	Smith 7	Owl's Club	No	Parking lot is a grass/gravel driveway, thresholds to doors are 1.5". Door handles are standard knobs.
5401	South Franklin 1	South Franklin Twp. Community Bldg.	No	Door is 29" double door, door handles are knobs, ramps are 16.1% and 11.7%
5402	South Franklin 2	South Franklin VFD	No	Threshold 1.5"
5503	South Strabane 3	Laboratory Presby Church	No	Ramp is 17.3%, threshold is 2" door is 31" interior walkway 32"
5601	Speers	Speers Boro Bldg	No	Ramp goes from 7.3% to 10.8% to get into the building.
6101	West Bethlehem	West Beth VFD	No	2.5" step to entrance.
6202	West Brownsville 2	Blainsburg Bible Church	No	Threshold > .5"
6302	West Finley 2	West Finley Grange Hall	No	Gravel, unsigned parking lot, steps to doors.
6401	West Middletown	West Middletown VFD	No	Old cracked sidewalk, threshold changes from 1-3" because it is on a slope. No parking.
6631	Washington 3-1	Wrights Zion Memorial Church	No	No parking, ramp in rear of building isn't possible to use because it has a grass approach.
6652	Washington 5-2	West Industrial Tire	No	Designate parking, ramp is 14.6%
6663	Washignton 6-3	St. Paul Lutheran Church	No	Door is 29" and lot is gravel
6671	Washington 7-1	Gandy Interval Garage	No	No designated parking, walkway to door is on a hill, 15.8% slope. Door is 29" with standard door knobs.
6672	Washington 7-2	Fourth Presbyterian Church	No	Ramp is 9.3%, door is 31"
6673	Washington 7-3	Calvary Temple Church	No	Doors are 30" slope of ramp to door is 15.5% and 10.6%
6674	Washington 7-4	Ace Glass and Mirror	No	Steps to every entrance, no designated parking.

Accessibility of Polling Sites

185 of 185

61 - Yes / 72 - Modify / 52 - No 33% Accessible
With Modifications 72%

6701	Green Hills	Lone Pine Country Club	No	Door with ramp is 28" and no designated parking.
0101	Allenport	Allenport Boro. Bldg	Yes	
0301	Beallsville	Beallsville Civic Assoc.	Yes	
0601	Buffalo	Buffalo Twp. Bldg	Yes	lot is tiny gravel
0701	Burgettstown	Burgettstown Senior Center	Yes	(Public Service Announcement)
0801	California 1	California Boro Bldg.	Yes	
1002	Canton 2	Holy Trinity National Catholic Social Hall	Yes	
1003	Canton 3	Canton Twp. Bldg	Yes	
1004	Canton 4	Friendship Community Church	Yes	
1005	Canton 5	Canton Twp VFD	Yes	
1102	Carroll 2	Ringgold High School	Yes	
1104	Carroll 4	Carroll Twp. Bldg	Yes	
1201	Cecil 1	Iceoplex at Southpointe	Yes	
1301	Centerville 1	American Legion #705	Yes	
1302	Centerville 2	Centerville Boro Bldg	Yes	
1403	Charleroi 3	Crest Ave Apts	Yes	
1404	Charleroi 4	Char House	Yes	
1504	Chartiers 4	Worstell Residence	Yes	Private Residence, ADA has no governing.
1505	Chartiers 5	PA Trolley Museum	Yes	
1507	Chartiers 7	Chartiers Twp. Bldg	Yes	
1801	Cokeburg	Cokeburg VFD	Yes	
1903	Cross Creek 3	Alvella High School	Yes	
2201	Donora 1	Church of Our Lady of the Valley	Yes	
2301	Dunlevy	Dunlevy Recreation Bldg	Yes	
2501	East Finley 1	Roadside Chapel	Yes	(As long as voting occurs in main ramped building.)
2901	Fallowfield 1	Fallowfield Twp Bldg	Yes	
2903	Fallowfield 3	Charleroi High School	Yes	
3301	Houston	Houston Boro Bldg	Yes	
3402	Independence 2	Avella VFD	Yes	
3701	Marianna	Marianna Boro Bldg	Yes	
3931	Monongahela 3-1	Monongahela City Hall	Yes	
4102	Mt. Pleasant 2	Fort Cherry Ambulance Social Hall	Yes	(Public Service Announcement)
4501	North Charleroi 1	North Charleroi VFD Lock #4	Yes	sign?
4502	North Charleroi 2	North Charleroi VFD Lock #4	Yes	sign?

Accessibility of Polling Sites

185 of 185

61 - Yes / 72 - Modify / 52 - No 33% Accessible
With Modifications 72%

4701	North Strabane 1	North Strabane Twp Bldg	Yes	Concerned about slope of interior ramps, but building inspector was not very nice to be around and I did not have the digital level this day.
4704	North Strabane 4	North Strabane VFD	Yes	
4706	North Strabane 6	North Strabane VFD	Yes	
4801	Nottingham 1	Nottingham Twp Bldg	Yes	
4911	Peters A-1	South Hills Bible Chapel	Yes	(Public Service Announcement)
4912	Peters A-2	Our Redeemer Lutheran Church	Yes	(Public Service Announcement)
4913	Peters A-3	South Hills Bible Chapel	Yes	(Public Service Announcement)
4921	Peters B-1	Peters Creek UP Church	Yes	
4922	Peters B-2	Peters Twp Community Rec Center	Yes	(Public Service Announcement)
4923	Peters B-3	Wrights United Methodist Church	Yes	
4931	Peters C-1	St Benedicts Church	Yes	
4932	Peters C-2	St Benedicts Church	Yes	
4941	Peters D-1	Peters Twp Community Rec Center	Yes	(Public Service Announcement)
4942	Peters D-2	Lakeside Church	Yes	
5301	Somerset 1	Somerset Twp Bldg	Yes	
5302	Somerset 2	Somerset Twp Bldg	Yes	
5501	South Strabane 1	South Strabane Twp Bldg	Yes	
5502	South Strabane 2	South Strabane Twp Bldg	Yes	
5504	South Strabane 4	South Strabane VFD	Yes	
5505	South Strabane 5	South Strabane VFD	Yes	
5901	Union 1	Gastonville Elementary	Yes	
5902	Union 2	Union Twp Municipal Bldg	Yes	
5904	Union 4	Elrama VFD	Yes	
5905	Union 5	Finleyville Middle School	Yes	Parking isn't close but it works.
5906	Union 6	Gastonville Elementary	Yes	
6501	West Pike Run 1	Grace United Methodist Church	Yes	
6621	Washington 2-1	Washington High School	Yes	
6651	Washington 5-1	Trinity Episcopal Church	Yes	